



NOTE :

- * Replace one shot therm—O—disc with L300F—60FXX14
- ** Replace Auto—Reset with Therm—O—Disc type 64TXX11—L165F
- *** Power supply wiring per NEC & Local Codes Suitable for at least 75 °C
- Use copper conductor wiring only.
- Field wire, NEC Class 1
- 24VAC, Class 2 power source must not exceed 26.4VAC under any primary input voltage condition per U.L./NEC.

Model	WGS 1005
Serial #	_____
Tag -	_____
Kilowatts	10.0
Volts—Ph—Hz	480 / 3 / 60
Control Volts	24
Steps	2
Heater Amps	12.0
Heater Fuses	N/A
_____	_____
_____	_____

SIMILAR TO CPHEATER061A00

WGS1005

Rev. by : M. REEVES
Date : 10/07/14

WARREN TECHNOLOGY

Control Wiring -----
Power Wiring _____
Field Wiring _____