


WKF — 0381 / 0502



Model	_____
Serial #	_____
Tag —	_____
Kilowatts	3.75 / 4.6
Volts-Ph-Hz	208/230/1/60
Control Volts	24.0
Steps	1
Heater Amps	18.1 / 20.0

WKF-0381/0502

NOTE :
CAUTION — Contactors utilize 22-28VDC coils with AC to DC rectifiers. Do not use contactor without rectifier. Replace with factory authorized parts only.
 — Contactor must always utilize AC-DC Rectifier with Time Delay as shown.
 ** Replace Auto-Reset with Therm-O-Disc type 60TX11-L165.
 *** Replace Lock-Out Limit with 36TXV12 — 150°C To Reset Lock-Out Limit, Cycle Power To The Heater With Either The Circuit Breaker Or The Thermostat.
 **** 24VAC, Class 2 power source must not exceed 26.4VAC under any primary input voltage condition per UL/NEC.
 ***** Power supply wiring per NEC & Local Codes. Suitable for at least 75°C.
 Use copper conductor wiring only.

Control Wiring _____
 Power Wiring _____
 Field Wiring _____

WKF0502

Rev. by : M. REEVES

Date : 05/02/18

WARREN TECHNOLOGY