



Model _____
 Serial # _____
 Tag - _____
 Kilowatts _____
 Volts-Ph-Hz _____
 Control Volts _____
 Steps _____
 Heater Amps _____
 Circuit Breakers _____

WKS-0805A
 8.0
 480/3Y/60
 24.0
 1
 9.6
 N/A

NOTE :
 *Replace service loops with SL-075A
 ** Replace Auto-Reset with Therm-O-Disc type F165-X
 *** Power supply wiring per NEC & Local Codes. Suitable for at least 75°C.
 Use copper conductor wiring only.
 **** 24VAC, Class 2 power source must not exceed 26.4VAC under any primary input voltage condition per UL/NEC.