



NOTE :

CAUTION - Contactors utilize 22-28VDC coils with AC to DC rectifiers. Do not use contactor without rectifier. Replace with factory authorized parts only.

- Contactor must always utilize AC-DC Rectifier with Time Delay as shown.

*Replace service loops with SL-075B

** Replace Auto-Reset with Therm-O-Disc type 60TX11-L165

*** 24VAC, Class 2 power source must not exceed 26.4VAC under any primary input voltage condition per UL/NEC.

**** Power supply wiring per NEC & Local Codes. Suitable for at least 75°C.

Use copper conductor wiring only.

Control Wiring

Power Wiring

Field Wiring

Model WKS-1502S
 Serial # _____
 Tag - _____
 Kilowatts 14.4
 Volts-Ph-Hz 240-1-60
 Control Volts 24.0
 Steps 2
 Heater Amps 60.0
 Circuit Breakers See C.B. above

WKS1502S

Rev. by : M. REEVES

Date : 02/27/15

WARREN TECHNOLOGY