



NOTE :

- CAUTION - Contactors utilize 22-28VDC coils with AC to DC rectifiers. Do not use contactor without rectifier. Replace with factory authorized parts only.
- Contactor must always utilize AC-DC Rectifier with Time Delay as shown.
- * Replace "Service Loop" with SL-075B
- ** Replace Auto-Reset with Therm-O-Disc type 60TX11-L165/64TX11-L165
- *** 24VAC, Class 2 power source must not exceed 26.4VAC under any primary input voltage condition per UL/NEC.
- **** Power supply wiring per NEC & Local Codes. Suitable for at least 75°C.

Control Wiring -----
 Power Wiring _____
 Field Wiring _____

Model	WUH-1502B
Serial #	_____
Tag -	_____
Kilowatts	15.00
Volts-Ph-Hz	240/1/60
Control Volts	24.0
Steps	2
Heater Amps	20.8/41.7
Circuit Breakers	See C.B. above