INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WGM0502B	**VOLTS:**	208-1P	240-1P
TAG: BAYEAAC05BK1A	**HTR WATTS:**	3600	4800
*=A,T page 2 of 2	**HTR AMPS:**	17.3	20.0

	EQUIPMENT MODEL NO	**MCA**	**MOCP**	**MCA**	**MOCP**
	TAM9A0 A24, B30, C36, C42	26	30	29	30
	TAM9A0 C48	28	30	31	35
	TAM9A0 C60	30	30	33	35

WARREN TECHNOLOGY