

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WGM0504	VOLTS:	208 3P	240 3P
	HTR WATTS:	3600	4800
* = A, T page 1 of 2	HTR AMPS:	10.0	11.5

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
GAM5A(B)0 A18, A24, B30	16.0	20	18.0	20
GAM5A(B)0 B36, C42	18.0	20	20.0	20
GAM5A(B)0 C48	20.0	20	22.0	25
GAM5A(B)0 C60	22.0	25	24.0	25
*AM40 A18	16.0	20	18.0	20
*AM40 A24, A30	15.0	15	17.0	20
*AM40, GAM2A0 A36	16.0	20	17.4	20
*AM40 B42,C48	17.0	20	19.0	20
*AM40 C60	22.0	25	24.0	25
GAT2A0, GAM2A0 B42	15.9	20	17.8	20
GAT2A0, GAM2A0 C48	16.4	20	18.3	20
GAT2A0, GAM2A0 C60	22.0	25	23.4	25
GAM2A0 A18	15.0	15	16.9	20
GAM2A0 A24, A30	14.6	15	16.5	20

