

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WGM0505	VOLTS:		480-3P
	HTR WATTS:		4800
* = A, T	HTR AMPS:		5.8

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
GAM5A(B)0 A18, A24, B30			7.25	15
GAM5A(B)0 B36, C42			7.25	15
GAM5A(B)0 C48			7.25	15
GAM5A(B)0 C60			7.25	15
*AM40 A18, A24, A30, A36			7.25	15
*AM40 B42, C48, C60			7.25	15
GAT2A0, GAM2AO B42			7.25	15
GAT2A0, GAM2AO C48			7.25	15
GAT2A0, GAM2AO C60			7.25	15
GAM2AO A18,A24,A30,A36			7.25	15
TAM9A0 A24, B30, C36, C42, C48, C60			7.25	15

