

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

| | | | |
|--|-------------------|--------|--------|
| MODEL NO: WGM1002B | VOLTS: | 208-1P | 240-1P |
| TAG: BAYEAAAC10BK1A page 2 of 2 | HTR WATTS: | 7200 | 9600 |
| *=A, T / NR=not recommended | HTR AMPS: | 34.6 | 40.0 |

| EQUIPMENT MODEL NO | MCA | MOCP | MCA | MOCP |
|---------------------------|------------|-------------|------------|-------------|
| TAM9A0 A24, B30, C36, C42 | 48 | 50 | 54 | 60 |
| TAM9A0 C48 | 50 | 50 | 56 | 60 |
| TAM9A0 C60 | 51 | 60 | 58 | 60 |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

