INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WGM1004	**VOLTS:**	208-3P	240-3P
TAG: BAYEAAC10LG3	**HTR WATTS:**	7200	9600
* = A, T page 2 of 2	**HTR AMPS:**	20.0	23.1

	EQUIPMENT MODEL NO	**MCA**	**MOCP**	**MCA**	**MOCP**
	TAM9A0 A24, B30, C36, C42	29	30	33	35
	TAM9A0 C48	31	35	34	35
	TAM9A0 C60	32	35	36	40

WARREN TECHNOLOGY