

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WGM1004	VOLTS:	208-3P	240-3P
TAG: BAYEAAC10LG3A	HTR WATTS:	7200	9600
* = A, T page 1 of 2	HTR AMPS:	20.0	23.1

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
GAM5A(B)0 A18,A24,B30	28.5	30	32.4	35
GAM5A(B)0 B36,C42	30.1	35	34.0	35
GAM5A(B)0 C48	32.5	35	36.4	40
GAM5A(B)0 C60	34.5	35	38.4	40
*AM40 A18, A24, A30, A36	28.0	30	31.9	35
*AM40, B42, C48	28.9	30	32.8	35
*AM40 C60	34.5	35	38.4	40
GAT2A0, GAM2A0 B42	28.4	30	32.3	35
GAT2A0, GAM2A0 C48	28.9	30	32.8	35
GAT2A0, GAM2A0 C60	34.5	35	38.4	40
GAM2A0 A18	27.5	30	31.4	35
GAM2A0 A24, A30	27.1	30	31	35
GAM2A0 A36	28	30	31.9	35

