

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WGM1005	VOLTS:		480-3P
	HTR WATTS:		9600
* = A, T	HTR AMPS:		11.5

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
GAM5A(B)0 A18, A24, B30			14.4	15
GAM5A(B)0 B36, C42			14.4	15
GAM5A(B)0 C48			14.4	15
GAM5A(B)0 C60			14.4	15
*AM40 A18, A24, A30, A36			14.4	15
*AM40 B42, C48, C60			14.4	15
GAT2A0, GAM2AO B42			14.4	15
GAT2A0, GAM2AO C48			14.4	15
GAT2A0, GAM2AO C60			14.4	15
GAM2AO A18,A24,A36			14.4	15
TAM9A0 A24, B30, C36, C42, C48, C60			14.4	15

