

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WGM1502B(S)	VOLTS:	208 1P	240 1P
TAG: BAYEABC15BK1A	HTR WATTS:	10800	14400
* = A, T page 1 of 2	HTR AMPS:	34.6-17.3	40.0-20.0

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
GAM5A(B)0 B30, B36, C42	48-22	50-25	55-25	60-25
GAM5A(B)0 C48, C60	53-22	60-25	60-25	60-25
*AM4AO, GAM2AO A30	45-22	45-25	52-25	60-25
*AM4AO, GAM2AO A36	46-22	50-25	53-25	60-25
*AM4AO B42, C48/ GAT2AO, GAM2AO B42, C48	47-22	50-25	54-25	60-25
*AM4AO C60/ GAT2AO, GAM2AO C60	53-22	60-25	60-25	60-25
SINGLE POINT				
GAM5A(B)0 B30, B36, C42	70	70	80	80
GAM5A(B)0 C48, C60	75	80	85	90
*AM4AO A30, A36, B42, C48, GAM2AO A30, A36	69	70	79	80
*AM4AO C60	75	80	85	90
GAT2AO, GAM2AO B42, C48	69	70	79	80
GAT2AO, GAM2AO C60	75	80	85	90

