INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WGM1504	**VOLTS:**	208-3P	240-3P
TAG: BAYEABC15LG3	**HTR WATTS:**	10800	14400
* = A, T page 2 of 2	**HTR AMPS:**	30.0	34.6

	EQUIPMENT MODEL NO	**MCA**	**MOCP**	**MCA**	**MOCP**
	TAM9A0 B30, C36, C42	41	45	47	50
	TAM9A0 C48	43	45	49	50
	TAM9A0 C60	45	45	50	50

WARREN TECHNOLOGY