

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WGM1504	VOLTS:	208-3P	240-3P
TAG: BAYEABC15LG3A	HTR WATTS:	10800	14400
* = A, T page 1 of 2	HTR AMPS:	30.0	34.6

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
GAM5A(B)0 B30	41	45	46.8	50
GAM5A(B)0 B36, C42	42.6	45	48.4	50
GAM5A(B)0 C48	45	45	50.8	60
GAM5A(B)0 C60	47	50	52.8	60
*AM40 A30	39.6	40	45.4	50
*AM40 A36	40.5	45	43.3	45
*AM40 B42, C48	41.4	45	47.1	50
*AM40 C60	47.0	50	52.8	60
GAT2A0, GAM2A0 B42	40.9	45	46.6	50
GAT2A0, GAM2A0 C48	41.4	45	47.1	50
GAT2A0, GAM2A0 C60	47.0	50	52.8	60
GAM2A0 A30	39.6	40	45.4	45
GAM2A0 A36	40.5	45	46.3	50

