

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WGM2002B(S)	VOLTS:	208-1P	240-1P
TAG: BAYEABC20BK1A	HTR WATTS:	14400	19200
* = A, T page 2 of 2	HTR AMPS:	34.6-34.6	40.0-40.0

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
TAM9A0 C36, C42	48-43	50-45	54-50	60-50
TAM9A0 C48	50-43	50-45	56-50	60-50
TAM9A0 C60	51-43	60-45	58-50	60-50
SINGLE POINT				
TAM9A0 C36, C42	90.9	100	104.4	110
TAM9A0 C48	92.8	100	106.3	110
TAM9A0 C60	94.5	100	108	110

