

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WGM2004		VOLTS:	208-3P	240-3P	
		HTR WATTS:	14400	19200	
* = A, T		HTR AMPS:	40.0	46.2	
EQUIPMENT MODEL NO		MCA	MOCP	MCA	MOCP
	GAM5A(B)0 C48	58	60	65	70
	GAM5A(B)0 C60	60	60	67	70
	*AM40 B42, C48	53.9	60	61.6	70
	*AM40 C60	59.5	60	67.3	70
	GAT2A0, GAM2A0 B42	53.4	60	61.1	70
	GAT2A0, GAM2A0 C48	53.9	60	61.6	70
	GAT2A0, GAM2A0 C60	59.5	60	67.3	70
	TAM9A0 C36, C42	54.3	60	62.1	70
	TAM9A0 C48	56.3	60	64.0	70
	TAM9A0 C60	58	60	65.8	70

