

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WGM2005	VOLTS:		480-3P
	HTR WATTS:		19200
* = A, T	HTR AMPS:		23.1

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
GAM5A(B)0 C48			28.9	30
GAM5A(B)0 C60			28.9	30
*AM40 B42, C48, C60			28.9	30
GAT2A0, GAM2AO B42			28.9	30
GAT2A0, GAM2AO C48			28.9	30
GAT2A0, GAM2AO C60			28.9	30
TAM9A0 C36, C42, C48, C60			28.9	30

