

## CROSS REFERENCE

<b>WARREN WUH SERIES ELECTRIC HEATERS</b>	<b>ARMSTRONG DATE: 07-29-09</b>	<b>ARMSTRONG BCS2 AIR HANDLER UNITS</b>
---	-------------------------------------	---

### WUH SERIES

WARREN MODEL#	ARMSTRONG MODEL#	KW	VOLT/ PHASE	FOR USE WITH	AMPS	STEPS
WUH 0502	AEHBCC05NSA-1	5.0	240/1	BCS2 018-060	20.8	1
WUH0502B	AEHBCC05CSA-1	5.0	240/1	BCS2 018-060	20.8	1
WUH0752	AEHBCC07NSA-1	7.5	240/1	BCS2 018-060	31.3	2
WUH0752B	AEHBCC07CSA-1	7.5	240/1	BCS2 018-060	31.3	2
WUH1002	AEHBCC10NSA-1	10.0	240/1	BC2S 018-060	41.6	2
WUH1002B	AEHBCC10CSA-1	10.0	240/1	BCS2 018-060	41.6	2
WUH1502B	AEHBCC15CSA-1	15.0	240/1	BCS2 030-060	62.4	3
WUH2002B	AEHBCC20CSA-1	20.0	240/1	BCS2 042-060	80.0	4
WUH0504	N/A	5	240/3	BCS2 030-060	12.0	1
WUH0754	N/A	7.5	240/3	BCS2 030-060	18.1	1
WUH1004	N/A	9	240/3	BCS2 030-060	21.65	1
WUH1504	N/A	15	240/3	BCS2 030-060	31.1	2
WUH2004	N/A	20	240/3	BCS2 042-060	47.8	2
WUH0505*	N/A	5	480/3	BCS2 030-060	6.0	1
WUH1005*	N/A	10	480/3	BCS2 030-060	12.0	1
WUH1505*	N/A	15	480/3	BCS2 030-060	18.1	1
WUH2005*	N/A	20	480/3	BCS2 042-060	24.1	1
WUH0505A**	N/A	5	480/3	BCS2 030-060	6.0	1
WUH1005A**	N/A	10	480/3	BCS2 030-060	12.0	1
WUH1505A**	N/A	15	480/3	BCS2 030-060	18.1	1
WUH2005A**	N/A	20	480/3	BCS2 042-060	24.1	1

'B' DENOTES CIRCUIT BREAKER (S)

\*REQUIRES DUAL POINT LINE FEED CONNECTIONS

\*\*-"A" DENOTES 480 VOLT TO 240 VOLT AUTO TRANSFORMERS FOR SINGLE POINT LINE FEED CONNECTION (AUTO TRANSFORMER MOUNTS EXTERNAL TO AHU)

- GALVANIZED CONSTRUCTION
- OVERTEMPERATURE LIMIT PROTECTION
- ANTI-CYCLING MAGNETIC CONTACTORS PER 5 KW STEPS
- TIME DELAY BETWEEN STEPS
- HACR CIRCUIT BREAKERS (B VERSION)
- INTERNAL MOUNT ONLY
- LOW VOLTAGE WIRING HARNESS WITH MODULAR PLUG

### WARREN TECHNOLOGY

2050 W 73 ST \* HIALEAH, FL 33016-9912 \* TEL (305) 556-6933 \* FAX (305) 557-6157

Website: [www.warrenhvac.com](http://www.warrenhvac.com)