

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WKF0302	VOLTS:	208 1P	230 1P	
TAG: CE/KFCEH0401N03	HTR WATTS:	2250	2760	
CE0401N03	HTR AMPS:	10.8	12.0	
EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
FA4A,FA4B,FB4B,FC4C 018-024	16.0	20	17.5	20
FB5A 018-024/FV4C 002-006	16.0	20	17.5	20
FY4A,FA4C,FC4B,FC4C,FC4D 018-024	16.0	20	17.5	20
FH4A,FH4B,FH4C 001-002	16.0	20	17.5	20
PF1MNA 018-024,PF4MNA 018-024	15.8	20	17.3	20
FX4A,FX4B,FX4C 018-024	15.8	20	17.3	20
FB4A,FB4C,FY5B 018-024	16.0	20	17.5	20
FE4A,FE5A 002-006	16.0	20	17.5	20
FX4D 018-024	15.9	20	17.3	20
FA4B,FB4B,FC4C 30-070	20.0	20	21.5	25
FX4C,FC4D,FX4B,FY4A,FA4C 030-060	20.0	20	21.5	25
FZ4A 024	15.9	20	17.3	20

