

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WKF1002B	VOLTS:	208 1P	230 1P	
TAG: CE/ KFCEH1101C10/ 2601C10	HTR WATTS:	7500	9200	
CE1101C10/CE2601C10	HTR AMPS:	36.1	40.0	
EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
FA4A 018-070	52.2	60	56.9	60
FB5A 018-070	52.2	60	56.9	60
FB4B,FC4C,FC4D,FA4B 018-070/FV4C 002-006	53.8	60	58.5	60
FH4A 001-004/FK4C 001-006	52.2	60	56.9	60
FX4A,FX4C,FC4D,FB4C,FY5B 018-061	53.8	60	58.5	60
FV4A,FV4B 002-006/FA4C,FY4A 018-060	53.8	60	58.5	60
40FKA,FK4D 001-006	53.8	60	58.5	60
PF1MN 018-061,PF4MN 018-061,FX4D 019-061	53.8	60	58.5	60
FB4A,FC4B 018-070	52.2	60	56.9	60
FE4A,FE5A 002-006	52.2	60	56.9	60
FX4B 030-060/FH4B,FH4C 001-004	53.8	60	58.5	60
FZ4A 024-061	53.8	60	58.5	60

