

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WKF1502B	VOLTS:	208 1P	230 1P	
TAG: SIM TO: KFCEH1701C15/ 3101C15	HTR WATTS:	11250	13800	
CE1701C15/CE3101C15	HTR AMPS:	36.2-18.1	40.0-20.0	
EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
FA4A, FB4A, FC4B, FB5A 024-070	52.2-22.7	60-25	56.9-25	60-25
FH4A 001-004, FK4C, FV4A 001-006	52.2-22.7	60-25	56.9-25	60-25
FE4A, FE5A, FV4B, FV4C 002-006	53.8-22.7	60-25	58.5-25	60-25
FX4C, FX4D, FC4D, FY4A, FA4C, FB4C, FY5B 024-061	53.8-22.7	60-25	58.5-25	60-25
FX4A, FX4B 030-060	53.8-22.7	60-25	58.5-25	60-25
40FKA, FK4D 001-006	53.8-22.7	60-25	58.5-25	60-25
FA4B, FB4B, FC4C 024-070	53.8-22.7	60-25	58.5-25	60-25
PF1MN, PF4MN 024-061	53.8-22.7	60-25	58.5-25	60-25
FH4B, FH4C 001-004	53.8-22.7	60-25	58.5-25	60-25
FZ4A 024-061	53.8-22.7	60-25	58.5-25	60-25

