

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WKF1802BS		VOLTS:	208 - 1P	230 - 1P	
		HTR WATTS:	13500	16560	
		HTR AMPS:	64.9	72.0	
EQUIPMENT MODEL NO		MCA	MOCP	MCA	MOCP
PF1MN,PF4MN 030-061		85.1	90	97.5	100
FV4B, FV4C, FE4A, FE5A 002-006		89.6	90	97.5	100
FK4D 001-006		89.6	90	97.5	100
FY4A, FA4C, FX4B, FY5B 030-060		87.6	90	96.5	100
FC4D, FB4C, FX4C, FX4D 030-060		85.1	90	97.5	100
FV4A, 40FKA 001-006		89.6	90	98.5	100
FX4A 030-060		87.6	90	96.5	100
FH4A 002-004		87.9	90	96.8	100
FA4A, FB4A, FC4B 030-070		87.9	90	96.8	100
FH4B, FH4C 002-004		87.9	90	96.8	100
FA4B, FB4B, FC4C 030-070		87.9	90	96.8	100
FK4C 001-006		89.6	90	97.5	100

