

**INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL**

<b>MODEL NO:</b> WKS0502B	<b>VOLTS:</b>	208 1P	240 1P
<b>TAG:</b> HKSC05XC	<b>HTR WATTS:</b>	3600	4800
Page 1 of 2	<b>HTR AMPS:</b>	17.3	20.0

<b>EQUIPMENT MODEL NO</b>	<b>MCA</b>	<b>MOCP</b>	<b>MCA</b>	<b>MOCP</b>
ARPT 18B,24B,30B / ARUF 18B,24B, 25B,29B,30B,31B	24	25	28	30
ARPT 36C / ARUF 36C,37C,37D,42C,43C,49C	26	30	29	30
ARPT 36D	26	30	29	30
ARPT 42D, 48D / ARUF 43D,47D,48D,49D	26	30	30	30
ARPT 60D / ARUF 60D,61D	28	30	31	35
AVPTC / DVPTC 24B, 25B, 30C, 33C, 35B	27	30	30	30
AVPTC / DVPTC 36C, 42D, 48D, 60D	27	30	30	30
AVPTC / DVPTC 29B, 31C, 36C, 37B, 37C, 37D, 39C	28	30	32	35
AVPTC / DVPTC 42C, 42D, 48C, 49C, 49D	28	30	32	35
AVPTC / DVPTC 48D, 59C, 59D, 60D, 61D	30	35	34	35
ASPT 24B / ASUF 29B	25	30	28	30
ASPT 30C, 36C / ASUF 39C	26	30	29	30
ASUF 42D	28	30	31	35
073018R				

