

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WKS0505	VOLTS:		480-3P	
	HTR WATTS:		4800	
	HTR AMPS:		5.8	
EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
ARPT 18B,24B,30B / ARUF 18B,24B,25B,29B,30B,31B			7.3	15
ARPT 36C,36D / ARUF 36C,37C,37D,42C,43C,49C			7.3	15
ARPT 42D,48D / ARUF 43D,47D,48D,49D			7.3	15
ARPT 60D / ARUF 60D,61D			7.3	15
AVPTC / DVPTC 24B, 25B, 30C, 33C, 35B			7.3	15
AVPTC / DVPTC 29B, 31C, 36C, 37B, 37C, 37D, 39C			7.3	15
AVPTC / DVPTC 42C, 42D, 48C, 49C, 49D			7.3	15
AVPTC / DVPTC 48D, 59C, 59D, 60D, 61D			7.3	15
ASPT 24B / ASUF 29B			7.3	15
ASPT 30C, 36C / ASUF 39C			7.3	15
ASPT 42D			7.3	15
ASPT 48D, 60D, 61D, / ASUF 59D			7.3	15
ASUF 49C			7.3	15
080218R				

