

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WKS0602	VOLTS:	208 1P	240 1P
TAG: HKSX06XC	HTR WATTS:	4500	6000
Page 1 of 2	HTR AMPS:	21.7	25.0

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
ARPT 18B,24B,30B / ARUF 18B,24B,25B,29B,30B,31B	30	30	34	35
ARPT 36C / ARUF 36C, 37C, 37D, 42C, 43C, 49C	32	35	36	40
ARPT 36D	31	35	35	40
ARPT 42D, 48D / ARUF 43D, 47D, 48D, 49D	32	35	36	40
ARPT 60D / ARUF 60D, 61D	33	35	37	40
AVPTC / DVPTC 24B, 25B, 30C, 33C, 35B	32	35	36	40
AVPTC / DVPTC 29B, 31C, 36C, 37B, 37C, 37D, 39C	34	35	38	40
AVPTC / DVPTC 42C, 42D, 48C, 49C, 49D	34	35	38	40
AVPTC / DVPTC 48D, 59C, 59D, 60D, 61D	36	40	40	40
ASPT 24B / ASUF 29B	30	35	34	35
ASPT 30C, 36C / ASUF 39C	31	35	35	40
ASPT 42D	33	35	37	40
080218R				

