

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WKS0802	VOLTS:	208 1P	240 1P
TAG: HKSX08XC	HTR WATTS:	6000	8000
Page 1 of 2	HTR AMPS:	28.9	33.3

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
ARPT 18B,24B,30B / ARUF 18B,24B,25B,29B,30B,31B	39	40	44	45
ARPT 36C / ARUF 36C, 37C,37D,42C,43C,49C	41	45	46	50
ARPT 36D	40	40	46	50
ARPT 42D, 48D / ARUF 43D,47D,48D,49D	41	45	46	50
ARPT 60D / ARUF 60D,61D	42	45	48	50
AVPTC / DVPTC 24B, 25B, 30C, 33C, 35B	41	45	47	50
AVPTC / DVPTC 29B, 31C, 36C, 37B, 37C, 37D, 39C	43	45	48	50
AVPTC / DVPTC 42C, 42D, 48C, 49C, 49D	43	45	48	50
AVPTC / DVPTC 48D, 59C, 59D, 60D, 61D	45	45	50	60
ASPT 24B / ASUF 29B	39	40	48	50
ASPT 30C, 36C / ASUF 39C	40	40	46	50
ASPT 42D	42	45	48	50
073018R				

