INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WKS0804	**VOLTS:**	208-3P	240-3P
	HTR WATTS:	6000	8000
Page 2 of 2	**HTR AMPS:**	16.7	19.2

	EQUIPMENT MODEL NO	**MCA**	**MOCP**	**MCA**	**MOCP**
	ASPT 48D, 60D, 61D / ASUF 59D	30	30	33	35
	ASUF 49C	35	35	31	35
	080318R				

WARREN TECHNOLOGY