

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WKS1004	VOLTS:	208-3P	240-3P
	HTR WATTS:	6750	9000
page 2 of 2	HTR AMPS:	18.7	21.7

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
ASPT 25B,29B	29.1	30	32.9	35
ASPT 33C,39C,49C	30.5	35	34.3	35
ASPT 37B,37C,47C,47D	29	30	32.8	35
ASPT 59C	31.3	35	35	35
ASPT 49D, 61D	32	35	35.8	40
050417R				

