

**INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL**

<b>MODEL NO:</b> WKS1081B/ WKS1502B		<b>VOLTS:</b>	208 1P	240 1P
<b>TAG:</b> HKSC15XA/ HKSC15XB		<b>HTR WATTS:</b>	10810	14400
		<b>HTR AMPS:</b>	34.6-17.3	40.0-20.0
<b>EQUIPMENT MODEL NO</b>	<b>MCA</b>	<b>MOCP</b>	<b>MCA</b>	<b>MOCP</b>
ARPT 30B / ARUF 30B,31B	46-22	50-25	53-25	60-30
ARPT 36C / ARUF 36C, 37C,37D,42C,43C,49C	48-22	50-25	54-25	60-30
ARPT 36D	48-22	50-25	54-25	60-30
ARPT 42D, 48D / ARUF 43D,47D,48D,49D	48-22	50-25	55-25	60-30
ARPT 60D / ARUF 60D,61D	50-22	50-25	56-25	60-30
AVPTC 36C, 42D, 48D	50-22	50-25	57-25	60-25
AVPTC 60D	52-22	60-25	59-25	60-25
ASPT 30C, 36C / ASUF 39C	47-22	60-25	54-25	60-25
ASPT 42D	49-22	50-25	56-25	60-25
ASPT 48D, 60D, 61D / ASUF 59D	52-22	60-25	58-25	60-25
ASUF 49C	50-22	60-25	57-25	60-25

