

**INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL**

<b>MODEL NO:</b> WKS1081S / WKS1502S	<b>VOLTS:</b>	208 1P	240 1P
	<b>HTR WATTS:</b>	10810	14400
	<b>HTR AMPS:</b>	51.9	60.0

<b>EQUIPMENT MODEL NO</b>	<b>MCA</b>	<b>MOCP</b>	<b>MCA</b>	<b>MOCP</b>
ARPT 30B / ARUF 30B,31B	68	70	78	80
ARPT 36C / ARUF 36C, 37C,37D,42C,43C,49C	70	70	79	80
ARPT 36D	70	70	79	80
ARPT 42D, 48D / ARUF 43D,47D,48D,49D	70	70	80	80
ARPT 60D / ARUF 60D,61D	72	80	81	90
AVPTC 36C, 42D, 48D	72	80	82	90
AVPTC 60D	74	80	84	90
ASPT 30C, 36C / ASUF 39C	69	70	75	80
ASPT 42D	71	80	81	90
ASPT 48D, 60D, 61D / ASUF 59D	74	80	83	90
ASUF 49C	72	80	82	90

