

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WKS1504	VOLTS:	208 3P	240 3P
TAG: HKSC15XF	HTR WATTS:	10800	14400
page 1 of 2	HTR AMPS:	30.0	34.6

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
ARPT 30B / ARUF 30B, 31B	40	40	46	50
ARPT 36C / ARUF 36C, 37C, 37D, 42C, 43C	42	45	48	50
ARPT 36D	42	45	47	50
ARPT 42D, 48D / ARUF 43D,47D, 48D, 49C, 49D	42	45	48	50
ARPT 60D / ARUF 60D, 61D	44	45	49	50
AVPTC 29B,31C,36C37B,37D,39C,42D,48D,49C,49D	44	45	50	50
AVPTC 60D,61D	47	50	52	60
ASPT 30C, 36C / ASUF 39C	42	45	48	50
ASPT 42D	44	45	50	50
ASPT 48D, 60D,/ ASUF 59C	46	50	52	60
ASUF 49C	45	45	50	50
072618R				

