

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WKS1505A	VOLTS:		480-3P	
	HTR WATTS:		13.5	
	HTR AMPS:		16.2	
EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
ARPT 30B / ARUF 30B,31B			21.4	25
ARPT 36C,36D / ARUF 36C,37C,37D,42C,43C,49C			22.2	25
ARPT 42D,48D / ARUF 43D,47D,48D,49D			22.4	25
ARPT 60D / ARUF 60D,61D			23.1	25
AVPTC / DVPTC 30C,33B,35B			22.7	25
AVPTC / DVPTC 36C,37B,37C,37D,39C			23.5	25
AVPTC / DVPTC 42D,48C,48D,49C,49D			23.5	25
AVPTC / DVPTC 59C,59D,60D,61D			24.6	25
ASPT 30C, 36C / ASUF 39C			22.2	25
ASPT 42D			23.3	25
ASPT 48D, 60D, 61D / ASUF 59D			24.4	25
ASUF 49C			23.6	25
072618R				

