

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WKS1501B/ WKS2002B		VOLTS:	208 1P	240 1P
TAG: HKSC19CA, HKSC20DA/		HTR WATTS:	14400	19200
HKSC19CB, HKS20DB		HTR AMPS:	46-23	53-27
EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
ARPT 36C / ARUF 36C,37C,37D,42C,43C,49C	48-44	50-45	54-50	60-60
ARPT 36D	48-44	50-45	54-50	60-60
ARPT 42D,48D / ARUF 43D,47D,48D,49D	48-44	50-45	55-50	60-60
ARPT 60D / ARUF 60D,61D	50-44	50-45	56-50	60-60
AVPTC 36C, 42D, 48D	48-44	50-45	54-50	60-60
AVPTC 60D	48-44	50-45	54-50	60-60
ASPT 36C / ASUF 39C	49-43	50-45	54-50	60-50
ASPT 42D	49-43	50-45	56-50	60-50
ASPT 48D, 60D, 61D / ASUF 59D	52-43	60-45	58-50	60-50
ASUF 49C	50-43	60-45	57-50	60-50

