

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WKS2004	VOLTS:	208-3P	240-3P	
	HTR WATTS:	12750	17000	
	HTR AMPS:	35.4	40.9	
EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
ARPT 36C,36D / ARUF 36C,37C,37D,42C,43C,49C	49	50	55.0	60
ARPT 42D,48D / ARUF 43D,47D,48D,49D	49	50	56	60
ARPT 60D / ARUF 60D,61D	50	50	57	60
AVPTC 36C, 42D, 48D	51	60	60	60
AVPTC 60D	53	60	60	60
ASPT 36C / ASUF 39C	49	50	56	60
ASPT 42D	51	60	58	60
ASPT 48D, 60D / ASUF 59D	53	60	60	60
ASPT 61D	53	60	60	60
ASUF 49C	51	60	58	60
111717R				

