

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WKF0802B	VOLTS:	208 1P	230 1P
TAG: EHK07AKB1	HTR WATTS:	6000	7360
	HTR AMPS:	28.8	32.0

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
EBP1800A-6000A, FXM4X 18-60	44.5	45	48.5	50
EBP1800B-6000B, WAP(M,T) 18-60	44.5	45	48.5	50
EBX2400A-6000A	44.5	45	48.5	50
EBV2400A-6000A	44.5	45	48.5	50
FEM, FSM, FSU,FVM (2,4) 1800A-6000A	44.5	45	48.5	50
WAH(M,T) 18-60, FCM4X 24-60	44.5	45	48.5	50

