

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WKF1002(T)	VOLTS:	208 1P	230 1P
TAG: EHK10AKN1	HTR WATTS:	7500	9200
page 1 of 2	HTR AMPS:	36.1	40.0

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
EBP1800A-6000A, FXM4X 18-60	53.6	60	58.5	60
EBP1800B-6000B, WAP(M,T) 18-60	53.6	60	58.5	60
EBX2400A-6000A	53.6	60	58.5	60
EBV2400A-6000A	53.6	60	58.5	60
FEM, FSM, FSU,FVM (2,4) 1800A-6000A	53.6	60	58.5	60
WAH(M,T) 18-60, FCM4X 24-60	53.6	60	58.5	60

