

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WGM0505A	VOLTS:		480-3P
	HTR WATTS:		4800
* = A, T	HTR AMPS:		5.8

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
GAM5A(B)0 A18, A24, B30			9.0	15
GAM5A(B)0 B36, C42			9.8	15
GAM5A(B)0 C48			11	15
GAM5A(B)0 C60			12	15
* AM40 A18, A24, A30, A36			8.8	15
* AM40 B42, C48			9.2	15
* AM40 C60			12.0	15
GAT2A0, GAM2AO B42			8.9	15
GAT2A0, GAM2AO C48			9.2	15
GAT2A0, GAM2AO C60 / TAM9A0 C60			12.0	15
GAM2AO A18			8.5	15
GAM2AO A24,A30,A36			8.8	15
TAM9A0 A24, B30, C36, C42			9.1	15
TAM9A0 C48			10.4	15

