

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WGM0805A	VOLTS:		480-3P
	HTR WATTS:		7680
* = A, T	HTR AMPS:		9.24

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
GAM5A(B)0 A18, A24, B30			13.3	15
GAM5A(B)0 B36, C42			14.1	15
GAM5A(B)0 C48			15.3	20
GAM5A(B)0 C60			16.3	20
*AM40 A18, A24, A30, A36			13.1	15
*AM40 B42, C48			13.5	15
*AM40 C60			16.3	20
GAT2A0, GAM2AO B42			13.2	15
GAT2A0, GAM2AO C48			13.5	15
GAT2A0, GAM2AO C60 / TAM9A0 C60			16.3	20
GAM2AO A18			12.8	15
GAM2AO A24,A30,A36			13.1	15
TAM9A0 A24, B30, C36, C42			13.4	15
TAM9A0 C48			14.7	15

