

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WGM1205A	VOLTS:		480-3P	
	HTR WATTS:		12000	
* = A,T	HTR AMPS:		14.4	
EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
GAM5A(B)0 B30			19.8	20
GAM5A(B)0 B36, C42			20.6	25
GAM5A(B)0 C48 / TAM9A0 C60			21.8	25
GAM5A(B)0 C60			22.8	25
*AM40 A30, A36			19.5	20
*AM40 B42, C48			19.9	20
*AM40 C60			22.8	25
GAT2A0, GAM2AO B42			19.7	20
GAT2A0, GAM2AO C48			19.9	20
GAT2A0, GAM2AO C60			22.8	25
GAM2AO A30			19.1	20
GAM2AO A36			19.5	20
TAM9A0 A24, B30, C36, C42			20.2	25
TAM9A0 C48			21.1	25

