

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WGM1505A	VOLTS:		480-3P
	HTR WATTS:		14400
* = A,T	HTR AMPS:		17.3

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
GAM5A(B)0 B30			23.4	25
GAM5A(B)0 B36, C42			24.2	25
GAM5A(B)0 C48			25.4	30
GAM5A(B)0 C60			26.4	30
*AM40 A30, A36			23.1	25
*AM40 B42, C48			23.6	25
*AM40 C60			26.4	30
GAT2AO, GAM2AO B42			23.3	25
GAT2AO, GAM2AO C48			23.6	25
GAT2AO, GAM2AO C60 / TAM9A0 C60			26.4	30
GAM2AO A30			22.7	25
GAM2AO A36			23.1	25
TAM9A0 B30, C36, C42			23.8	25
TAM9A0 C48			24.8	25

