INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WBC0505A	**VOLTS:**	480-3P
	HTR WATTS:	5000
	HTR AMPS:	6.01

	EQUIPMENT MODEL NO	**MCA**	**MOCP**
	BCS3, BCE3 18, 24, 30, 36, 42	8.9	15
	BCS3, BCE3 18, 60	9.9	15
	CBX25 18, 24, 3, 36, 42	8.9	15
	CBX25 48, 60	9.9	15

WARREN TECHNOLOGY