

**INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL**

<b>MODEL NO:</b> WBC1005	<b>VOLTS:</b>	480-3P
	<b>HTR WATTS:</b>	1000
	<b>HTR AMPS:</b>	12.03

<b>EQUIPMENT MODEL NO</b>	<b>MCA</b>	<b>MOCP</b>
BCS3, BCE3 18, 24, 30, 36, 42	15.1	20
BCS3, BCE3 48, 60	15.1	20
CBX25 18, 24, 30, 36, 42	15.1	20
CBX25 48, 60	15.1	20

