

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WBC1252S	VOLTS:	208-1P	240-1P
	HTR WATTS:	9375	12500
	HTR AMPS:	45.0	52.1

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
SINGLE POINT				
BCS3, BCE3 30, 42	50.3	60	67.0	70
BCS3, BCE3 36	51.1	60	68.0	70
BCS3, BCE3 48, 60	52.6	60	70.0	70
CBX25 30, 42	54.0	60	66.0	70
CBX25 36	59.0	60	68.0	70
CBX25 48, 60	61.2	70	70.0	70

