

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: WBC2004	VOLTS:	208-3P	240-3P
	HTR WATTS:	13650	18200
	HTR AMPS:	37.9	43.8

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
BCS3, BCE3 48, 60	50.3	60	57.6	60
CBX25 048, 060	52.3	60	59.6	60