

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: W6K0802B	VOLTS:	208 1P	240 1P
TAG: 6HK16500806	HTR WATTS:	5760	7680
page 2 of 2	HTR AMPS:	27.7	32.0

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
AHV 18B,24B,30B	38.0	40	42.9	45
AHV 36C,42D	39.2	40	44.0	45
AHV 48D,60D	41.3	45	46.1	50
AE 18B,24B,30B	39.0	40	42.7	45
AE 36B,36C,42C	40.9	45	44.6	45
AE 48C,48D,60C,60D	43.4	45	47.1	50
AVC 18B,24B,30B	38.6	40	42.2	45
AVC 36B,36C,42C	41.1	45	44.2	45
AVC 48C,48D,60C,60D	44	45	47.3	50
AVV 25B, 37B, 37C, 38C	41.1	45	44.2	45
AVV 49C, 49D, 50D, 61C, 61D	44	45	47.3	50
RFCX 18BE, 22BE, 24BE, 30BE	38.2	43.5	40	45
RFCX 34CE, 36CE, 42DE	39.8	45.1	40	50
RFCX 48DE, 60DE	42.2	47.5	45	50

