

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: W6K1002	VOLTS:	208 1P	240 1P
TAG: 6HK06501006	HTR WATTS:	7200	9600
Page 1 of 2	HTR AMPS:	34.6	40.0

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
AHR 18B, 24B	44.92	45	49.67	50
AHR 30B, 36B	47.63	50	52.67	60
AHR 42C, 48D, 60D	47.6	50	52.7	60
AHE 18B, 22B, 24B, 30B	46.83	50	51.42	60
AHE 34C, 36C, 42D	48.46	50	53.04	60
AHE 48D, 60D	50.8	60	55.04	60
AP 18B	44.6	45	49.2	50
AP 24B	45.0	45	49.6	50
AP 30B	46.1	50	50.7	60
AP 36B	46.5	50	51.1	60
AP 36C, 37C	46.0	50	50.6	60
AP 42C	46.8	50	51.3	60
AP 48C, 48D	46.9	50	51.5	60
AP 60C, 60D	48.4	50	53.0	60

