

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: W6K1002B	VOLTS:	208 1P	240 1P
TAG: 6HK16501006	HTR WATTS:	7200	9600
PAGE 2 OF 2	HTR AMPS:	34.6	40.0

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
AHV 18B,24B,30B	46.7	50	52.9	60
AHV 36C,42D	47.8	50	54.0	60
AHV 48D,60D	50.0	50	56.1	60
AE 18B,24B,30B	47.4	50	52.0	60
AE 36B,36C,42C	49.3	50	53.8	60
AE 48C,48D,60C,60D	51.8	50	56.3	60
AVC 18B,24B,30B	47	50	51.5	60
AVC 36B,36C,42C	49.5	50	53.5	60
AVC 48C,48D,60C,60D	52.4	60	56.6	60
AVV 25B, 37B, 37C, 38C	49.5	50	53.5	60
AVV 49C, 49D, 50D, 61C, 61D	52.4	60	56.6	60
RFCX 18BE,22BE, 24BE, 30BE	46.8	53.5	50	60
RFCX 34CE, 36CE, 42DE	48.5	55.1	50	60
RFCX 48DE, 60DE	50.8	57.5	60	60

