

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: W6K1004	VOLTS:	208-3P	240-3P
TAG: 6HK36501025	HTR WATTS:	7200	9600
PAGE 2 OF 2	HTR AMPS:	20.0	23.1

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
AE 18B, 24B, 30B	28.3	30	30.9	35
AE 36B, 36C, 42C	29.8	30	32.4	35
AE 48C, 48D, 60C, 60D	31.8	35	34.4	35
AVC 18B, 24B, 30B	28.8	30	31.3	35
AVC 36B, 36C, 42C	31.3	35	33.3	35
AVC 48C, 48D, 60C, 60D	34.2	35	36.4	40
AVV 25B, 37B, 37C, 38C	31.3	35	33.3	35
AVV 49C, 49D, 50C, 50D, 61C, 61D	34.2	35	36.4	40
RFCX 18BE, 22BE, 24BE, 30BE	28.5	32.4	30	35
RFCX 34CE, 36CE, 42DE	42.6	48.4	45	50
RFCX 48DE, 60DE	32.5	36.4	35	40

