

INSTALLER CHECK APPROPRIATE BOX AND PLACE LABEL ON OUTSIDE ACCESS PANEL

MODEL NO: W6K1502B(S)	VOLTS:	208 1P	240 1P
TAG: 6HK16501506	HTR WATTS:	10800	14400
PAGE 2 OF 5	HTR AMPS:	51.9	60.0

EQUIPMENT MODEL NO	MCA	MOCP	MCA	MOCP
AP 30B	43.3-24.5	45-25	47.9-26.8	50-30
AP 36B	43.3-24.9	45-25	47.9-27.2	50-30
AP 36C, 37C	43.3-24.4	45-25	47.9-26.7	50-30
AP 42C	43.3-25.2	45-30	47.9-27.5	50-30
AP 48C, 48D	43.3-25.3	45-30	47.9-27.6	50-30
AP 60C, 60D	43.3-26.8	45-30	47.9-29.1	50-30
SINGLE POINT	67.8	70	74.6	80
AP 30B	68.2	70	75.0	80
AP 36B	67.7	70	74.5	80
AP 36C, 37C	68.4	70	75.2	80
AP 42C	68.5	70	75.4	80
AP 48C, 48D	70.0	70	76.9	80
AP 60C, 60D				

